



January 3, 2019

Town of Wolseley
Box 310
WOLSELEY, SK
S0G 5H0

Dear Waterworks Owner/Operator:

RE: Rescinding - Precautionary Drinking Water Advisory – Town of Wolseley

The Water Security Agency, in consultation with the Regina Qu'Appelle Health Region, is advising that the "Precautionary Drinking Water Advisory" (PDWA) issued by the Water Security Agency for a portion of the distribution system of Wolseley's potable water has been rescinded, as of January 3, 2019.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The water main repair has been completed;
- The distribution system has been pressurized, and flushed, according to applicable standards;
- The receipt of bacteriological sample collected test negative for bacteriological growth in the final treated potable water.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Town of Wolseley in addressing the advisory.

Thank you for your cooperation in this regard. For further information please do not hesitate to contact the undersigned at (306) 787-4584.

Sincerely,

A handwritten signature in black ink that reads "Rod Broadfoot".

Rod Broadfoot, EPO
Environmental Services Section - South
Environmental and Municipal Management Services Division
Water Security Agency

cc: Greg Holovach, Drinking Water and Wastewater Management Division
Regina Qu'Appelle Health Region
Water Security Agency - Drinking Water and Wastewater Management Division